

Liste des Indisponibilités Critiques par Zone d’Influence pour le calcul de capacité Long terme FR-UK

Les Indisponibilités Critiques sont les ouvrages du réseau de RTE dont l’indisponibilité est susceptible de limiter la capacité de la zone d’influence dans laquelle l’indisponibilité se produit.

Une Zone d’Influence est une zone géographique, comprenant une liste d’ouvrages du réseau de RTE, partageant les mêmes contraintes.

Zone d’Influence “IFA2000/ElecLink”

Cette Zone d’Influence comprend deux interconnexions FR-UK : IFA2000 et ElecLink.

Au sein de cette zone d’influence, les ouvrages suivants sont susceptibles d’avoir un impact sur les capacités d’IFA2000 et d’ElecLink en cas d’indisponibilité :

- Liaison 400kV N0 2 ATTAQUES (LES) – MANDARINS
- Liaison 400kV N0 1 MANDARINS – WARANDE
- Liaison 400kV N0 2 ATTAQUES (LES) – WARANDE
- Liaison 400kV N0 1 AVELIN-MASTAING
- Liaison 400kV N0 2 AVELIN-MASTAING
- Liaison 400kV N0 2 AVELGEM-AVELIN

Zone d’Influence “IFA2000/ElecLink”

Cette Zone d’Influence comprend une seule interconnexion FR-UK : IFA2.

Au sein de cette zone d’influence, les ouvrages suivants sont susceptibles d’avoir un impact sur les capacités d’IFA2 en cas d’indisponibilité :

- Liaison 400kV N0 1 TERRETTE-TOURBE
- Liaison 400kV N0 2 TERRETTE-TOURBE
- Liaison 400kV N0 1 TAUTE-TERRETTE
- Liaison 400kV N0 2 TAUTE-TERRETTE
- Liaison 400kV N0 1 ROUGEMONTIER-TOURBE
- Liaison 400kV N0 2 ROUGEMONTIER-TOURBE
- Liaison 400kV N0 1 BARNABOS-ROUGEMONTIER
- Liaison 400kV N0 2 BARNABOS-ROUGEMONTIER

List of the Critical Outages for each Area of Influence in the Long-Term capacity calculation on the FR-UK border

The critical Outages are grid elements on the French transmission network that might limit the capacity of an Area of Influence in case they have an outage.

An Area of Influence is a geographic area that contains a list of grid elements that share the same constraints.

“IFA2000/ElecLink” Area of Influence

This Area of Influence contains two FR-UK interconnections: IFA2000 and ElecLink.

Inside that Area of Influence, the outage of the following grid elements might have an impact on the commercial capacity of IFA2000 and ElecLink:

- Line 400kV NO 2 ATTAQUES (LES) – MANDARINS
- Line 400kV NO 1 MANDARINS – WARANDE
- Line 400kV NO 2 ATTAQUES (LES) – WARANDE
- Line 400kV NO 1 AVELIN-MASTAING
- Line 400kV NO 2 AVELIN-MASTAING
- Line 400kV NO 2 AVELGEM-AVELIN

“IFA2” Area of Influence

This Area of Influence contains only one FR-UK interconnection: IFA2.

Inside that Area of Influence, the outage of the following grid elements might have an impact on the commercial capacity of IFA2:

- Line 400kV NO 1 TERRETTE-TOURBE
- Line 400kV NO 2 TERRETTE-TOURBE
- Line 400kV NO 1 TAUTE-TERRETTE
- Line 400kV NO 2 TAUTE-TERRETTE
- Line 400kV NO 1 ROUGEMONTIER-TOURBE
- Line 400kV NO 2 ROUGEMONTIER-TOURBE
- Line 400kV NO 1 BARNABOS-ROUGEMONTIER
- Line 400kV NO 2 BARNABOS-ROUGEMONTIER

